



产品认证证书

证书编号: CQC2016010301902636

申请人名称及地址

人民电器集团防爆电器有限公司
乐清市柳市镇智广工业区 (人民电器集团有限公司内)

制造商名称及地址

人民电器集团防爆电器有限公司
乐清市柳市镇智广工业区 (人民电器集团有限公司内)

生产企业名称及地址

人民电器集团防爆电器有限公司 (V053715)
乐清市柳市镇智广工业区 (人民电器集团有限公司内)

产品名称和系列、规格、型号

照明动力配电箱 (配电板)

FXMD InA=160A~16A, Icw=4kA; Ue=380V、220V, Ui=400V; 50Hz; IP65-操作面 IP30; 户内型

产品标准和技术要求

GB/T7251.3-2017

认证模式

型式试验+获证后监督

上述产品符合 CQC11-462176-2018 认证规则的要求, 特发此证。

发证日期: 2020年08月16日 有效期至: 2021年09月13日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

主任: _____

陆杨



中国质量认证中心

中国·北京·南四环西路188号9区100070

<http://www.cqc.com.cn>



PRODUCT CERTIFICATE

CERTIFICATE NO.: CQC2016010301902636

NAME AND ADDRESS OF THE APPLICANT

People electrical appliance group, explosion-proof electric appliance co., LTD
Two heads are better yueqing willow town industrial zone (people electrical appliance group co., LTD.)

NAME AND ADDRESS OF THE MANUFACTURER

People electrical appliance group, explosion-proof electric appliance co., LTD
Two heads are better yueqing willow town industrial zone (people electrical appliance group co., LTD.)

NAME AND ADDRESS OF THE FACTORY

People electrical appliance group, explosion-proof electric appliance co., LTD (V053715)
Two heads are better yueqing willow town industrial zone (people electrical appliance group co., LTD.)

PRODUCT NAME, MODEL AND SPECIFICATION

Distribution Boards

FXMD InA=160A~16A, Icw=4kA; Ue=380V、220V, Ui=400V; 50Hz; IP65-操作面 IP30; 户内型

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T7251.3-2017

TYPE OF CERTIFICATION SCHEMES

Type testing+Follow up factory inspection

This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC11-462176-2018 .

Valid from: Aug.16,2020

Valid until: Sep.13,2021

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

President: _____

Lu Mei



CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>

0 00000000