CW8074

2014002878Z

CNAS 检测 CNAS L1020

(2014)国认监认字(347)号

实验室名称：国家电器产品质量监督检验中心

Lab Name: China National Center for Quality Supervision and Test of Electrical Apparatus Products

№ 16Q1362-S

检验（试验）报告

Test Report

委托单位：江西人民输变电有限公司

Client:

产品名称：户外开闭所

Name of Product:

产品型号：RDW-12

Product Type:

检验类别：型式试验

Test Category:

本实验室对出具的检验（试验）结果负责，未经实验室书面同意，不得部分地复制本报告。

The laboratory is responsible for the inspection (Test) results. The report shall not be reproduced except in full, written approval of the laboratory.

国家电器产品质量监督检验中心	检 验 报 告	RDW-12 户外开闭所

检 验 结 论

委托单位	江西人民输变电有限公司	
试品型号	RDW-12	
试品名称	户外开闭所	
制造单位	江西人民输变电有限公司	
实施的检验项目及检验结果	防护等级检验[外壳：IP33D]	合格
	机械撞击试验[外壳：IK10]	合格
	气候防护试验[淋雨率：5mm/min 淋雨时间：5min]	合格
依据标准	GB/T 11022-2011《高压开关设备和控制设备标准的共用技术要求》中 6.7、附录 C	
	GB 3906-2006《3.6 kV～40.5 kV 交流金属封闭开关设备和控制设备》中 6.7、6.105	
检验结论	经过对江西人民输变电有限公司生产的 RDW-12 户外开闭所的检验，所检项目符合上述依据标准相应条款及产品技术文件的规定，检验结果合格。 注：本结论仅对送试样品负责。	

编制：陈伟 日期：2016-07-15 校对：刘俊强 日期：2016-07-15 审定：孙亿 日期：2016-07-15 批准：[illegible] 日期：2016-07-15